



# Patterson Irrigation District

## Pumping Plant 1 Flow Rate Max

<b>Start</b>	<b>10/01/2024 12:00:00 AM</b>
<b>End</b>	<b>10/01/2025 12:00:00 AM</b>

Report Generated 01/29/2026 11:29:56 AM

<b>PP1 Monthly Report - Hourly Maximum Flow (CFS)</b>		
<b>Date</b>	<b>PP1 Max Flow Rate (CFS) - Sontek</b>	<b>PP1 Max Flow Rate (CFS) - Sommers RQ-30</b>
<i>October</i>	102.0	120.6
<i>November</i>	105.6	117.4
<i>December</i>	0.0	32.7
<i>January</i>	0.0	8.2
<i>February</i>	74.9	85.9
<i>March</i>	94.6	103.0
<i>April</i>	153.6	215.1
<i>May</i>	166.9	183.9
<i>June</i>	164.6	188.3
<i>July</i>	159.2	183.7
<i>August</i>	142.4	160.4
<i>September</i>	error	148.7